

**IMPLEMENTING RULES AND REGULATIONS**  
**FOR THE**  
**MCMULLIN AREA GROUNDWATER SUSTAINABILITY AGENCY**  
**GROUNDWATER WELL METERING, MEASUREMENT, MONITORING**  
**AND CONSTRUCTION POLICY AND RELATED POLICIES**

(adopted October 6, 2021)

**1. Purpose**

- a) The purpose of this document is to provide specific guidance to landowners and their respective vendors and contractors when contemplating new and/or replacement well construction or retrofitting of existing wells, which are designed to produce more than two (2) acre feet of water annually, on lands within the boundary of the McMullin Area Groundwater Sustainability Agency (MAGSA) and the requisite acquisition and installation of well metering, measurement and/or monitoring hardware to assure compliance with the MAGSA's associated standing policies in that regard. Specifically, these Implementing Rules and Regulations outline the acceptable range of type, performance, accuracy and reliability of required hardware for compliance with said policies. As a Groundwater Sustainability Agency ("GSA"), properly organized pursuant to the Sustainable Groundwater Management Act ("SGMA"), MAGSA is authorized to adopt rules, regulations, ordinances, and resolutions for purposes of fulfilling its obligations as a GSA. (Water Code § 10725.2(b).) MAGSA adopts these Implementing Rules and Regulations pursuant to this authority.
- b) All newly constructed and/or replacement wells drilled within the MAGSA service area are subject to permit approval by the Fresno County Department of Public Health, Environmental Health Division, ("Fresno County Health") and shall be further regulated by MAGSA, as set forth herein. A new well is any well, designed to produce more than two (2) acre feet of water annually, that does not presently exist but is proposed to be constructed. A replacement well is a specific kind of new well that is located within 300 feet of an existing well, with the existing well appropriately designated for abandonment and destruction, and owned by the same Party that intends to construct the new well. Procedures set forth herein are not meant to duplicate or replace well permitting and well abandonment/destruction procedures implemented by Fresno County. Fresno County Health is cooperating with MAGSA by providing additional information to applicant landowners seeking to drill new or replacement wells within MAGSA on MAGSA's supplemental requirements to more easily facilitate compliance by the landowners and their contractors with these rules and regulations. **Fresno County Health is in no way responsible for enforcement of these rules and regulations.**
- c) Existing wells, not already in compliance with these rules and regulations, are subject to additional retrofitting and or modification requirements, as further set forth herein, in order to comply with SGMA and/or the policies adopted by MAGSA relative thereto.

## 2. Scope

2.1 These Implementing Rules and Regulations apply to any and all groundwater wells, designed to produce more than two (2) acre feet of water annually, currently existing within the MAGSA service area and/or to wells which shall be constructed during the period within which these rules and regulations shall be in effect and are intended to clarify the specifications for compliance with existing standing MAGSA policies, as appropriate.

## 3. Recitals

**WHEREAS**, MAGSA is a joint powers authority formed pursuant to the Joint Exercise of Powers Act (Gov't Code section 6500 et seq.) and acts pursuant to that authority;

**WHEREAS**, MAGSA's mission is to: (1) sustainably manage, protect and maintain the groundwater resources within the McMullin Area of the Kings Subbasin consistent with the Sustainable Groundwater Management Act of 2014 (Water Code section 10720 et seq.) ("SGMA") for the benefit of water users within the McMullin Area of the Kings Subbasin, Basin No. 5-22.08 as identified in the Department of Water Resources' ("DWR") Bulletin 118 and designated as subject to conditions of critical overdraft; and (2) to coordinate with other Groundwater Sustainability Agencies ("GSAs") and management activities throughout the region;

**WHEREAS**, pursuant to Water Code section 10725.2, the MAGSA Board of Directors is authorized to adopt rules, regulations, ordinances and resolutions for the purpose of complying with SGMA;

**WHEREAS**, MAGSA, in carrying out its mission, has a continuous need to acquire groundwater data, including, but not limited to, well location, well construction, geological information, water quality, water level data and extraction quantity (pumping data) from its landowners within the McMullin Area, and to compile and manage those data in a Confidential Data Management System;

**WHEREAS**, MAGSA has and plans to continue to develop and/or acquire confidential, technical and proprietary information related, but not limited to, well location, well construction, geological information, groundwater level data and extraction quantity (pumping data), groundwater production data and groundwater quality information for the McMullin Area ("Confidential Information") and desires to ensure that any Confidential Information that may be disclosed to MAGSA is treated in the strictest confidence consistent with the requirements of the law;

**WHEREAS**, MAGSA has adopted the following policies which remain as standing policies of MAGSA, the provisions of which are incorporated herein by reference as if set forth herein:

1. **Policy No. 2020-02**, dated June 3, 2020, entitled the McMullin Area Groundwater Sustainability Agency Accountability and Transparency Policy; and
2. **Policy No. 2020-06**, dated September 2, 2020, entitled the McMullin Area Groundwater Sustainability Agency Groundwater Data Policy; and

3. **Policy No. 2021-09**, dated February 3, 2021, entitled the McMullin Area Groundwater Sustainability Agency Groundwater Well Metering, Measurement, Monitoring and Construction Policy.

**WHEREAS**, the aforementioned policies contain language specifying adoption of clarifying implementing regulations to carry out their stated intent (please see policies for specific directives and references);

**NOW, THEREFORE, BE IT RESOLVED** that the following Implementing Rules and Regulations shall provide the clarifying implementing regulation as specified in said policies, shall be effective upon adoption, and shall remain in effect until further modified or rescinded.

### **Implementing Rules and Regulations**

#### **2021.01 Well Registration**

- a) All existing groundwater wells located within MAGSA’s service area designed to produce more than two (2) acre feet of water shall be registered with MAGSA no later than January 1, 2022.
- b) All new groundwater wells located within MAGSA’s service area designed to produce more than two (2) acre feet of water annually shall be registered with MAGSA no later than January 1, 2022 or within thirty (30) days of commencement of drilling for new well, whichever occurs later.
- c) “Registration” shall include (to the extent known to landowner at the time of registration) well owner’s (landowner) name and contact information, assessor’s parcel number, well geo-location, date of construction (or reasonable estimate), well construction detail, a copy of the well completion report (if available), overall depth of well, and other such relevant information, as may, from time to time by appropriate regulation or ordinance, be determined to be necessary by MAGSA for implementation of the GSP and compliance with SGMA.
- d) Groundwater well registration information shall be provided on a MAGSA issued confidential registration form, as the same may be amended and supplemented from time to time, an initial example of which is included as Attachment A to these rules and regulations.

#### **2021.02 Well Construction**

- a) All new groundwater wells, designed to produce more than two (2) acre feet of water annually, shall meet standards established in Department of Water Resources Bulletin 74 or as the same may be hereafter revised, or as established by Fresno County Department

of Public Health, Environmental Health Division, whichever is more stringent, and shall be subject to permitting as required by Fresno County Health.

- b) New groundwater wells and replacement groundwater wells, designed to produce more than two (2) acre feet of water annually, constructed within the MAGSA boundary, in addition to all hardware and appurtenant power supply requirements required for Fresno County permitting, shall, in addition, include all of the following:
  - i. An electromagnetic flow metering device that meets the specifications set forth herein in Section 2021.03;
  - ii. A water quality sampling spigot (90 degree from horizontal downward facing spigot, capable of producing a smooth and laminar flow) on the discharge piping; and
  - iii. A groundwater elevation sounding tube of at least one (1) inch in diameter, accessing the inside of the casing and constructed to a depth at least 100 feet below the existing static water level, to facilitate accurate water elevation measurements.

### **2021.03 Well Metering**

- a) MAGSA policy requires all groundwater wells designed to produce more than two (2) acre feet of water annually located within the MAGSA boundary to be outfitted with compliant electromagnetic flow metering devices on or before January 31, 2025. All newly constructed groundwater wells or replacement groundwater wells designed to produce more than two (2) acre feet of water annually are required to include an electromagnetic flow metering device on the new or replacement well at the time of construction thereof. In complying with these groundwater well metering requirements, all landowners and/or well owners shall ensure that all groundwater wells located within the MAGSA boundary have an electromagnetic flow metering device that meets the following criteria and/or specifications:
  - i. The meter shall be either a flange type or a saddle type meter;
  - ii. The meter shall be an electromagnetic flow meter and microprocessor based signal converter, capable of communicating with remote telemetry;
  - iii. The meter shall contain a flow sensor based on Faraday's law of electromagnetic induction;
  - iv. The meter shall be accurate to within  $\pm$  two percent (2%) of actual flow;
  - v. The meter shall report actual flow rate and contain an aggregate flow totalizer to capture production volume, with flow reported in cubic feet per second and total pumping reported in acre-feet;
  - vi. Each meter shall be appropriately sized for the production rate and discharge piping of the well;

- vii. Each meter shall have a measurement range that matches the expected range of production rates from the well on which it is installed.
- b) Installation of all meters shall be performed by a licensed contractor. Meters must be installed in strict adherence to all applicable manufacturer specifications.
- c) Testing and/or calibration of meters shall be performed by a licensed contractor intervals specified by the meter manufacturer. Calibration records shall be made available to MAGSA upon request.

#### **2021.04 Well Monitoring**

- a) Data collection, reporting and management are critical elements of the MAGSA Groundwater Sustainability Plan (GSP). The data will need to be collected, stored and managed in a precise, accurate and confidential manner to successfully place MAGSA in a position of achieving sustainability at the earliest possible time while maintaining the highest levels of confidentiality for landowners' proprietary information as allowed by law.
- b) While not requiring the installation of remote telemetry on each groundwater well, MAGSA encourages consideration by landowners to provide for that capability at the earliest possible time. Absent that feature, reporting must be accounted for manually and is subject to higher time and energy costs and human error in the transcription of the reported information. MAGSA intends to contract for secure data management services and that contractor will have remote telemetry recommendations which will provide maximum efficiencies in this regard.
- c) As indicated, accurate reporting is critical and groundwater well owners shall provide to MAGSA, through a method to be approved by the MAGSA Board, (either manually or telemetrically as identified above) meter reading and recordation of each groundwater well's groundwater production data on a monthly basis beginning on the first day of each month following the installation of its new groundwater meter or written confirmation from MAGSA that its existing meter meets the provisions of section 2021.03(a) above, and continuing thereafter for each successive month.
- d) Well owners shall transmit their groundwater production data for the prior month to MAGSA no later than the fifteenth (15<sup>th</sup>) day of the month following its collection.

#### **2021.05 Enforcement**

- a) While MAGSA enjoys tremendous support from its landowners and stakeholders in moving positively toward achievement of its sustainability goals, circumstances arise from time to time which require additional measures to assist in that regard.

- b) Landowners are expected to meet the obligations and deadlines established by these Implementing Rules and Regulations. Failure to comply will incur a warning that allows not more than 30 days to achieve compliance. Failure to meet the deadline established in the warning will result in MAGSA arranging for or performing the required work or task and the subsequent billing to the landowner for the any costs, charges or fees required to comply.
- c) Landowners shall be responsible for compliance with these rules and regulations by any lessee on their property.
- d) If MAGSA has cause to believe that a landowner's groundwater production is in excess of that reported to MAGSA by the landowner, MAGSA may request additional information from the landowner to substantiate the reported production amount.
- e) In the event the situation does not resolve itself to MAGSA's satisfaction, MAGSA may send the landowner a letter setting forth: (1) the nature and extent of the under reporting; (2) the steps that the entity must take in order to come into compliance; (3) a specific deadline for the entity to complete the necessary steps; and (4) a warning that MAGSA reserves the right to utilize additional legal and practical methods to compel the landowner to complete the requirements if the necessary steps are not completed by the specified deadline. Deadlines will be set based upon a reasonable estimate of the time necessary to complete the process.
- f) The remedies identified in these Implementing Rules and Regulations are not intended to be exclusive. Any other remedy available to MAGSA in law or equity may be employed at the discretion of MAGSA to address any circumstance related to management of the Basin in accordance with the SGMA, the MAGSA GSP, the MAGSA standing policies and these Implementing Rules and Regulations.

# Exhibit "A"

## (SAMPLE)

### WELL REGISTRATION FORM

McMullin Area Groundwater Sustainability Agency

The McMullin Area Groundwater Sustainability Agency (MAGSA) has adopted a Groundwater Well Metering, Monitoring and Construction Policy and Implementing Rules and Regulations detailing certain procedures relating to registration, construction, metering and monitoring of certain groundwater wells and related groundwater data sets pursuant to MAGSA's obligations under the Sustainable Groundwater Management Act (SGMA). Included in the Implementing Rules and Regulations is a requirement to register all wells designed to produce more than two (2) acre feet of water annually within the MAGSA boundary. Section 2021.01 of the Implementing Rules and Regulations provides as follows:

**2021.06 Well Registration**

- e) All existing groundwater wells located within MAGSA's service area designed to produce more than two (2) acre feet of water shall be registered with MAGSA no later than January 1, 2022.
- f) All new groundwater wells located within MAGSA's service area designed to produce more than two (2) acre feet of water annually shall be registered with MAGSA no later than January 1, 2022 or within thirty (30) days of commencement of drilling for new well, whichever occurs later.
- g) "Registration" shall include (to the extent known to landowner at the time of registration) well owner's (landowner) name and contact information, assessor's parcel number, well geo-location, date of construction (or reasonable estimate), well construction detail, a copy of the well completion report (if available), overall depth of well, and other such relevant information, as may, from time to time by appropriate regulation or ordinance, be determined to be necessary by MAGSA for implementation of the GSP and compliance with SGMA.

The following information is required for each well owned and operated within MAGSA:

Landowner (well owner) name and address, telephone contact and email:

Name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Telephone: \_\_\_\_\_

Email address: \_\_\_\_\_

Well location:

APN \_\_\_\_\_

Lat/Long: \_\_\_\_\_

Geolocation: \_\_\_\_\_

Township/Range/Section and Qtr Section: \_\_\_\_\_

Date of construction: \_\_\_\_\_

Status: Active \_\_\_\_ Inactive \_\_\_\_ Abandoned \_\_\_\_

Flow meter present? \_\_\_\_\_ Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_

Motor type: \_\_\_\_\_ Horsepower: \_\_\_\_\_

Pump efficiency testing within past three (3) years? \_\_\_\_\_

---

The following information is requested, if available, for each well owned and operated within MAGSA:

Well construction (well driller) reports

Video logs

Geologic logs

Pump type

Depth to water

Water elevation

Power source

Pump discharge pipe diameter

Current or past pump test results

Other information associated with specific well locations reasonably available (i.e repair invoices with temporal data, etc.)